



AVK Series 25 and 45 Gate Valves AWWA C509 Certificate of Compliance

This letter is to certify that all 3-inch through 16-inch Series 25 and Series 45, NRS, and OS&Y resilient wedge gate valves manufactured by American AVK Co. in Minden, Nevada, meet or exceed the standards established by AWWA for Resilient Seated Gate Valves; ANSI/AWWA C509.

The valves are rated by American AVK Company for a working pressure of 250 psi. Each valve is shell tested to 500 psi and tested for complete operation at 250 psi and 25 psi before shipment.

In addition, all American AVK gate valves have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information please feel free to contact us.

AMERICAN AVK COMPANY

2155 Meridian Blvd – Minden, NV. 89423 - Phone 775-552-1400 - Fax 775-783-7502
WWW.AVKUS.COM