



## **Series 25 and Series 45 Gate Valves UL/FM Certificate of Compliance**

This letter is to certify that all Series 25 and Series 45, 2-½-inches through 12-inches manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established UL and FM. The gate valves are listed with UL and ULC and are FM approved.

Each gate valve is tested, after assembly, to a static pressure of 500 psi. The UL and FM working pressure is rated to 200 psi for the Series 25 gate valves. The UL and FM working pressure is rated to 250 psi for the Series 45 gate valves.

In addition, all American AVK gate valves have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information please feel free to contact us.

---

**AMERICAN AVK COMPANY**

2155 Meridian Blvd – Minden, NV. 89423 - Phone 775-552-1400 - Fax 775-783-7502  
[WWW.AVKUS.COM](http://WWW.AVKUS.COM)