



AVK Series 41 Check Valves AWWA C508 Certificate of Compliance

This letter is to certify that all 3-inch through 12-inch Series 41 resilient seated and bronze seated check valves manufactured by American AVK Co. in Minden, Nevada, meet or exceed the standards established by AWWA for Swing Check Valves; ANSI/AWWA C508.

The valves are rated by American AVK Company for a working pressure of 250 psi. Each valve is shell tested to 500 psi and seal tested for complete operation at 250 psi.

If you have any questions or need further information please feel free to contact us.

AMERICAN AVK COMPANY

2155 Meridian Blvd – Minden, NV. 89423 - Phone 775-552-1400 - Fax 775-783-7502
WWW.AVKUS.COM