

SERIES 53 – BALL

CHECK VALVE OPTIONS

SERIES 53 – BALL CHECK VALVE OPTIONS

• End Connections

- ☐ FL x FL - Flange by Flange (2" - 24")
- ☐ NPT x NPT - National Pipe Thread x National Pipe Thread (1.5" and 2")

• Ball Coating

- ☐ NBR (Standard), Nitrile, Buna 'N'

• Valve Material

- ☐ Ductile Iron (Standard)
- ☐ 316 Stainless Steel (1.5" and 2" NPT only)

• Bolting

- ☐ Zinc Plated Steel (Standard)
- ☐ 304 Stainless Steel
- ☐ 316 Stainless Steel

• Coating

- ☐ Fusion Bonded Epoxy, 8 mils minimum thickness: to AWWA C550 (Standard)
- ☐ Black Alkyd (Standard 14" and larger)
- ☐ Holiday Free Interior – Fusion Bonded Epoxy only
- ☐ Holiday Free Exterior – Fusion Bonded Epoxy only
- ☐ Holiday Free Interior & Exterior – Fusion Bonded Epoxy only

- NOTE: These are generally available options for AVK AWWA check valves. Some options are not available for all valve types and sizes. Contact American AVK for details.

Customer: _____

Municipality: _____

Engineer: _____

Requested By: _____

Date: _____

Approver Name: _____

Signature: _____

Title: _____